



**GENERAL NOTES:**

1. BOTH THE 'Z' TYPE AND 'J' TYPE CONTINUOUS MOUNTING CLIPS ARE MADE OF 16 GA. BENT STEEL
2. THE PERFORATED FACE SHEET IS 22 GA. GALVANIZED PERF. WITH 3/8" HOLES ON 3/16" STAGGERED CENTERS
3. SPACER IS SELF-FURRING GALVANIZED LATH
4. FILL MATERIAL IS BAGGED FIBERGLASS ACOUSTIC FILL
5. MOUNTING FASTENERS DETERMINED BY EXISTING WALL SURFACE

**DETAIL 'B'**

**SOUND ABSORPTION COEFFICIENTS**

OCTAVE BAND CENTER FREQUENCIES (Hz)	125	250	500	1K	2K	4K	NRC
NB-IV (WITHOUT FILL PROTECTION)	0.70	1.08	1.15	1.05	1.05	1.01	1.10
NB-IV-B (WITH FILL PROTECTION AND SPACER)	0.78	1.10	1.19	1.04	1.02	0.81	1.10

\*All testing conducted by Riverbank Acoustical Laboratories. Sound Absorption Coefficients by the Reverberation Room Method ASTM C-423-02

REVISIONS		DESCRIPTION		CUSTOMER		DRAWING NO.	
DESCRIPTION	DATE	BY	DATE	SCALE	SHEET	1 of 1	NB-IV
<b>4" ABSORPTION PANEL</b>							
				<b>Noise Barriers, LLC</b> 2001 Kelley Court, Libertyville, IL 60048 Phone: 847-843-0500 Fax: 847-843-0501 www.noisebarriers.com			